

**GOVERNMENT OF INDIA
OFFICE OF THE CHIEF ENGINEER (E) NZ,
CPWD, EAST BLOCK-I, LEVEL-V, R.K. PURAM,
NEW DELHI-110066**

No. 42(11)/SW-I/CE(E)NZ/04/1364

Dated: - 24/11/16

To,

All the SE(E)'s
Under this Zone

APPROVAL OF BRAND


M/s Paragon Cables India had approached this office for regular use of their **ELEKTRON** brand ISI marked products in CPWD Works. The following items have been approved to be used in all the Projects being undertaken by CPWD in Northern Zone.

- (a) PVC insulated, Aluminium / Copper Conductor, Armoured / Unarmoured Cables :
(1.5 sq. mm to 1000 sq. mm ; upto 4 Cores for Power Cables & upto 61 Cores for Control Cables) suitable for 1.1 KV grade low tension transmission conforming to **IS:1554 (Part- I)**
- (b) XLPE insulated, Aluminium / Copper Conductor, Armoured / Unarmoured Cables :
(1.5 sq. mm to 1000 sq. mm ; upto 4 Cores for Power Cables & upto 61 Cores for Control Cables) suitable for 1.1 KV grade low tension transmission conforming to **IS:7098 (Part- I)**
- (c) PVC insulated, Aluminium / Copper Conductor Flexible Wires & Cords suitable for 1100 Volts grade Electric distribution in buildings etc. as per **IS : 694 (Part - I)**

The above approval does not absolve the executive / supervisory staff from their overall responsibility for using correct quality product. Mandatory checks about the quality shall be made and feed back / performance reports should be submitted to this office.

Further specifications / details of the products may be obtained directly from the manufacturer at the address given below:

M/s Paragon Cables India,
1/6, IIIrd Floor, East Patel Nagar,
New Delhi - 110008.
Tel: (011) 25884877, 25881557
Fax: (011) 25881125 ; email : mail@elektron.com


(J.K. Chaudhry)
CE, NZ, CPWD

Copy to :

M/s Paragon Cables India, 1/6, IIIrd Floor,
East Patel Nagar, New Delhi-110008.