

M.P. POORV KSHETRA VIDYUT VITARAN Co. Ltd.
BLOCK No. 7, SHAKTI BHAWAN, JABALPUR.

Tel: 0761-2702440, Fax: 0761-2660128

No.EZ/WS/JBIC/ 4375

JABALPUR, dt.28.12.07

To,

M/s Technical Associates Ltd.
D -25 , Dixit Enclave
Narmada Road,
Jabalpur (M.P.) - 482001

Fax No. : 0761 - 2661867

Sub:- Vendor approval for procurement of material against construction award under JBIC scheme for erection of new 33/11KV S/s alongwith associated 33KV & 11KV lines at Chhindwara, Seoni + Balaghat, Sidhi, Anuppur + Umariya, Jabalpur + Mandla district.

Sub:- This office Contract Award No.699, 700, 701, 702 & 703 dated 15.05.07.

Dear Sir,

This has reference to your letter No. TAL/JBP/JBIC/398 dt. 12.12.07 & PCI/APP./2007-08 Dated 27-12-07 requesting for vendor approval for procurement of different capacity of Armoured and unarmoured Alluminium power & copper control cables for which the status of vendor approval is indicated as hereunder :-

| SN | Name of firm for which Vendor Approval is required | Name of Item | Status |
|----|---|---|---|
| 1 | M/s Paragon Cable India,29, Rajsthan Udyog Nagar, G.T. Karnal Road, Delhi-110033 Phone- 911127691333 Fax- 911127691129 e-mail : pci@vsnl.net | COPPER CONTROL CABLES:- 2 C x 2.5 Sqmm. 10 C x 2.5 Sqmm. 12 C x 2.5 sqmm. PVC POWER CABLES :- 3.5 C x 70 sqmm. 4 C x 16 Sqmm. | Approved ,As per approved. GTPs enclosed. |

Encl.: Approved GTPs


Superintending Engineer(Works)
O/o Executive Director(WS-EZ)
MPPKVV Co. Ltd., Jabalpur

Copy to:-

1. The ED(JR)/CE(RR)/CE(SR), MPPKVV CO..LTD. Jabalpur/Rewa/Sagar.
2. M/s Star Delta Transformers Ltd., 92-A, Industrial Area, Govindpura, Bhopal.
3. M/s Bhasha Associates, 239, Naveen Nagar, Bhopal (M.P.)-462023.
4. M/s Cotrol Systems, Plot No.23, Sector-I, Govindpura Ind. Area, Bhopal.
5. M/s Narmada Transmission Pvt. Ltd., 6/1, Industrial Area, Govindpura, Bhopal.
6. M/s Eltel Engineers, 101, Lalbahadur Complex, New Bus Stand, Satna.
7. M/s Paragon Cable India,29, Rajsthan Udyog Nagar, G.T. Karnal Road, Delhi-110033

M.P.POORV KSHETRA VIDYUT VITARAN Co. Ltd.
BLOCK NO. 7, SHAKTI BHAWAN, JABALPUR.
Tel: 0761- 2702440, FAX: 0761- 2660128

No. EZ/WS/JBIC/736

Jabalpur, dt. 05-02-08

CORRIGENDUM

In supersession to this office letter No. EZ/WS/JBIC/264 dated 16.01.08 issued in respect of M/s Paragon Cable India, 29, Rajsthan Udyog Nagar, GT Karnal Road, Delhi-110033 regarding vendor approval of Copper Control Cables & PVC Power Cables for JBIC works, the revised status of approved items are indicated as hereunder.

| SN | Name of firm for which Vendor Approval is required | Name of Item | Status |
|----|---|--|---|
| 1 | M/s Paragon Cable India, 29, Rajsthan Udyog Nagar, GT Karnal Road, Delhi- 110033 | Copper Control Cables:- 2 Core x 2.5 sqmm. 4 Core x 2.5 Sqmm. 8 Core x 2.5 Sqmm. 12 Core x 2.5 Sqmm. PVC Power Cables: 1 Core x 50 Sqmm. 1 Core x 70 sqmm. 1 Core x 150 sqmm | Approved GTPs & Technical Specifications are enclosed. |

Encl: As above


Superintending Engineer(Works)
O/o Executive Director(WS-EZ)
MPPKVV Co. Ltd., Jabalpur

Copy to:-

1. The CE (JR)/(RR)/(SR), MPPKVV Co. Ltd. Jabalpur/Rewa/Sagar.
2. M/s Star Delta Transformers Ltd., 92-A, Industrial Area, Govindpura, Bhopal.
3. M/s Bhasha Associates, 239, Naveen Nagar, Bhopal (M.P.) - 462023
4. M/s Technical Associate Ltd., 8th Km., Faizabad Road, Ismailganj, Lucknow(U.P.)Branch
Office : D-25, Dixit Enclave, Bandariya Tiraha, Narnada Road, Jabalpur.
5. M/s Cotrol Systems, Plot No.23, Sector-1, Govindpura Ind. Area, Bhopal.
6. M/s Narmada Transmission Pvt. Ltd., 6/1, Industrial Area, Govindpura, Bhopal.
7. M/s Eltel Engineers, 10/1, Laibahadur Complex, New Bus Stand, Satna.
8. M/s Paragon Cable India, 29, Rajsthan Udyog Nagar, GT Karnal Road, Delhi-110033

Encl: As above.


M.P. POORV KSHETRA VIDYUT VITARAN Co. Ltd.
BLOCK No. 7, SHAKTI BHAWAN, JABALPUR.
Tel: 0761-2702440, Fax: 0761-2660128

No.EZ/WS/JBIC/1018

JABALPUR, dt. 19-2-08

CORRIGENDUM

In partial modification to this office corrigendum issued vide this office letter No.EZ/WS/JBIC/736 dated 05.02.08 it is to clarify that the use of single core XLPE cable as specified in corrigendum is optional. The power cable as specified in Bid specification could also be used. However, in case of copper control cable it should be solid core instead of stranded core.


Superintending Engineer(WS-EZ)
MPPKVV Co. Ltd., Jabalpur

Copy to:-

3. The CE(JR)/(RR)/(SR), MPPKVV CO. LTD. Jabalpur/Rewa/Sagar.
2. M/s Star Delta Transformers Ltd., 92-A, Industrial Area, Govindpura, Bhopal.
3. M/s Bhasha Associates, 239, Naveen Nagar, Bhopal (M.P.)-462023.
4. M/s Cotrol Systems, Plot No.23, Sector-I, Govindpura Ind. Area, Bhopal.
5. M/s Narmada Transmission Pvt. Ltd., 6/1, Industrial Area, Govindpura, Bhopal.
6. M/s Eltel Engineers, 101, Lalbahadur Complex, New Bus Stand, Satna.
7. M/s Technical Associate Ltd., 8th Km., Faizabad Road, Ismailganj, Lucknow (U.P.)
- 1/8. M/s Paragon Cable India, 29, Rajsthan Udyog Nagar, GT Karnal Road, Delhi-110033 Fax No.011 – 25881125, 27691129